

DECLARATION OF CONFORMITY	No. 09QD-18ENG/V2	Date 1.06.2017	CE 13
Product DISTRIBUTION CABLES OF RATED VOLTAGE $U_0 / U = 0.6 / 1$ kV			
Type HIKJ 0,6 / 1 kV			
Manufacturer Draka Keila Cables Ltd, Paldiski road 31, Keila 76606 Estonia			
Manufactured according to: IEC 60502-1 IEC 61034-1 (-2) IEC 60754-1 (-2)			
Fire performance according to IEC 60332-1-2 and EN 60332-1-2			
The goods have been inspected and tested in accordance with the abovementioned technical specifications and they were found to meet all requirements stated.			
The management system of the company has found to be in conformance to ISO 9001 and ISO 14001 and OHSAS 18001 standards			
Company follows and complies with the requirements of the European Commission Regulation LVD 2014/35/EU, REACH 2006/121/EC, RoHS 2011/65/EU; CPR305/2011/EU			

Draka Keila Cables



Derek Vaide
COO



Note: HD 603 S1- this Harmonization Document was approved by CENELEC on 1993 - 12 - 08. CENELEC members are bound to comply with the CEN / CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document on a national level.

